



Government Of West Bengal  
Office Of The Divisional Fire Officer, Malda  
West Bengal Fire & Emergency Services  
English Bazar Fire Station, Ghorapir, Malda. Pin :- 732101

Memo no.:EBFS/P/24/15

Date: 26-09-2022

**From:**  
Divisional Fire Officer, Malda  
West Bengal Fire & Emergency Services

**To:** MALDA INSTITUTE OF EDUCATION & TRAINING  
VILL-SONAJHURI, P.O-JHARPUKURIA, DIST-MALDA

**Sub:** Issuance of Fire Safety Certificate for existing construction of G+2 storied school Building Under group of Educational in the name of MALDA INSTITUTE OF EDUCATION AND TRAINING at the Premises no- JI.No-44, Plot No-351, Kh.No-454, Under Mouza-Panchgaw(Sonajhuri), Vill-Sonajhuri, P.O-Jharpukuria, Dist-Malda.

This is in reference to your application no. 0125189220800085 dated 23-09-2022 regarding the Issuance of Fire Safety Certificate for existing construction of G+2 storied school Building Under group of Educational in the name of MALDA INSTITUTE OF EDUCATION AND TRAINING at the Premises no- JI.No-44, Plot No-351, Kh.No-454, Under Mouza-Panchgaw(Sonajhuri), Vill-Sonajhuri, P.O-Jharpukuria, Dist-Malda.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be strictly maintained.
3. Existing Electrical wiring of the whole building shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
4. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
5. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
6. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
7. Fire Extinguisher Refilled after one year.
8. The Fire Safety Certificate is valid for three years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629\_L Dated-17/04/2018.
9. After three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

Signature valid

Digitally Signed:  
Name: Sanjib Kumar Das  
Date: 26-Sep-2022 17:17  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Malda  
West Bengal Fire & Emergency Services



Government Of West Bengal  
Office Of The Divisional Fire Officer, Malda  
West Bengal Fire & Emergency Services  
English Bazar Fire Station, Ghorapir, Malda. Pin :- 732101

Memo no.:EBFS/P/24/15

Date: 26-09-2022

**From:**

Divisional Fire Officer, Malda  
West Bengal Fire & Emergency Services

**To: MALDA INSTITUTE OF EDUCATION & TRAINING  
VILL-SONAJHURI, P.O-JHARPUKURIA, DIST-MALDA**

**Sub: Issuance of Fire Safety Certificate for existing construction of G+2 storied school Building Under group of Educational in the name of MALDA INSTITUTE OF EDUCATION AND TRAINING at the Premises no- JI.No-44, Plot No-351, Kh.No-454, Under Mouza-Panchgaw(Sonajhuri), Vill-Sonajhuri, P.O-Jharpukuria, Dist-Malda.**

This is in reference to your application no. 0125189220800085 dated 23-09-2022 regarding the Issuance of Fire Safety Certificate for existing construction of G+2 storied school Building Under group of Educational in the name of MALDA INSTITUTE OF EDUCATION AND TRAINING at the Premises no- JI.No-44, Plot No-351, Kh.No-454, Under Mouza-Panchgaw(Sonajhuri), Vill-Sonajhuri, P.O-Jharpukuria, Dist-Malda.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be strictly maintained.
3. Existing Electrical wiring of the whole building shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
4. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
5. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
6. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
7. Fire Extinguisher Refilled after one year.
8. The Fire Safety Certificate is valid for three years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629\_L Dated-17/04/2018.
9. After three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

Signature valid

Digitally Signed  
Name: SHILPA NANDA RAMAN  
Date: 26-September-2022 10:57  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Malda  
West Bengal Fire & Emergency Services